

PENRECO DIVISION OF PENNZOIL CO -- PETROFLUID 822 -- 9150-00-149-7431

===== Product Identification =====

Product ID:PETROFLUID 822

MSDS Date:01/01/1985

FSC:9150

NIIN:00-149-7431

MSDS Number: BDCPG

=== Responsible Party ===

Company Name:PENRECO DIVISION OF PENNZOIL CO

Address:700 MILIAM ST PENNZOIL PL

Box:2967

City:HOUSTON

State:TX

ZIP:77252

Country:US

Info Phone Num:800-245-3952

Emergency Phone N

um:800-245-3952

CAGE:JO941

=== Contractor Identification ===

Company Name:PENRECO DIVISION, PENNZOTL

Address:700 MILIAM ST PENNZOIL PL

Box:2967

City:HOUSTON

State:TX

ZIP:77252

Country:US

CAGE:JO941

Company Name:PENRECO, DIV OF PENNZOIL CO

Address:700 MILIAM ST

Box:2967

City:HOUSTON

State:TX

ZIP:77252

Country:US

Phone:800-245-3952

CAGE:86459

===== Composition/Information on Ingredients =====

Ingred Name:SYNTHETIC OIL

Ingred Name:DIBASIC ACID ESTER

===== Haza

Identification =====

Effects of Overexposure:EYE: IRRIT: SKIN: IRRIT. INGEST: LOCAL IRRIT OF MUC MEMB OF THOAT, MOUTH, ESOPHAGUS, STOMACH.

===== First Aid Measures =====

First Aid:EYE: WASH IMMEDIATELY WITH WATER FOR 15 MIN. CALL PHYSICIAN. SKIN:WASH WITH SOAP & WATER. REMOVE CONTAMINATED CLOTHING & WASH BEFORE REUSE. INGEST: DO NOT INDUCE VOMITING (ASPIRATION HAZARD)

===== Fire Fighting Measures =====

Flash Point Method:COC

Flash Point:424F,218C

Extinguishing Media:CO₂, DRY CHEM, FOAM

Fire Fighting Procedures:WATER MAY BE USED TO COOL HEAT-EXPOSED CANS.

Unusual Fire/Explosion Hazard:PROD OF COMBUSTION:CO, CO₂, SMOKE.

MATERIAL MUST BE HEATED ABOVE FLASH POINT TO BE A FIRE HAZARD.

===== Accidental Release Measures =====

Spill Release Procedures:SPREAD OIL DRY MATERIAL ON SPILL & SWEEP UP OR DILUTE SPILL WITH PETROLEUM SOLVENT & WIPE UP. PROVIDE ADEQUATE VENT &

AVOID SOURCES OF IGNITION. STORE IN COVERED MARKED METALLIC CONTAINERS AND DISPOSE OF AS SOON AS POSSIBLE.

===== Handling and Storage =====

Handling and Storage Precautions:STORE IN COVERED MARKED METALLIC CONTAINERS. STORE IN COOL WELL VENTED AREA. CONTROL IGNITION SOURCES. GROUND CANS PRIOR TO PUMPING OR TRANSFERRING.

Other Precautions:FIRE EXTINGUISHERS MUST BE KEPT READILY AVAILABLE & ALL PERSONNEL TRAINED PROPERLY. DO NOT MIX WITH STRONG

OXIDANTS. DO

NOT TRANSFER TO UNMARKED CONTAINERS. AUTOIGNITION TEMP: 630F;332C.

===== Exposure Controls/Personal Protection =====

Respiratory Protection:NIOSH/MSHA APPROVED RESPIRATOR FOR PARTICULAR EXPOSURE OF CONCERN.(MFR)

Ventilation:TO KEEP CONCENTRATION BELOW TLV. USE EXPLOSION-PROOF EQUIP.

Protective Gloves:POLYETHYLENE

Eye Protection:SAFETY GOGGLES WITH FACE SHIELD

Other Protective Equipment:IMPERVIOUS POLYETHYLENE BOOTS/APRON ETC.

Supplemental Safety and Health

TLV= 5M

G/CUM FOR MIST & 500 PPM FOR VAPORS GENERATED UPON
HEATING.CONTAINER: 1 QUART

===== Physical/Chemical Properties =====

HCC:V6

Vapor Pres:1

Spec Gravity:0.85

Evaporation Rate & Reference: