

AMERON INDUSTRIAL COATINGS DIVISION -- 786-104 -- 8010-00-161-7384

=====
Product Identification
=====

Product ID:786-104

MSDS Date:01/01/1985

FSC:8010

NIIN:00-161-7384

MSDS Number: BDDNB

=== Responsible Party ===

Company Name:AMERON INDUSTRIAL COATINGS DIVISION

Address:201 N BERRY ST

City:BREA

State:CA

ZIP:92621-3904

Country:US

Info Phone Num:714-529-4597

Emergency Phone Num:714-529-4597

CAGE:098

69

=== Contractor Identification ===

Company Name:AMERON INDUSTRIAL COATINGS DIVISION

Address:201 N BERRY ST

Box:City:BREA

State:CA

ZIP:92621-3904

Country:US

Phone:714-529-4597

CAGE:09869

=====
Composition/Information on Ingredients
=====

Ingred Name:ISOPROPYL ALCOHOL (SARA III)

CAS:67-63-0

RTECS #:NT8050000

Fraction by Wt: 5.0%

OSHA PEL:400 PPM/500 STEL

ACGIH TLV:400 PPM/500STEL;9192

Ingred Name:ISOBUTYL ALCOHOL (SARA III)

CAS:78-83-1

RTECS #:NP9625000

Fraction by Wt: 10.

0%
OSHA PEL:100 PPM
ACGIH TLV:50 PPM; 9293
EPA Rpt Qty:5000 LBS
DOT Rpt Qty:5000 LBS

Ingred Name:ETHYL BENZENE
RTECS #:XS5600000
Fraction by Wt: < 5%
ACGIH TLV:100 PPM

Ingred Name:ISOBUTYL ACETATE (SARA III)
CAS:110-19-0
RTECS #:AI4025000
Fraction by Wt: 28.0%
OSHA PEL:150 PPM
ACGIH TLV:150 PPM; 9192
EPA Rpt Qty:5000 LBS
DOT Rpt Qty:5000 LBS

Ingred Name:NAPHTHA (PETROLEUM SPIRITS OR BENZIN)
CAS:8030-30-6
RTECS #:SE7555000
Fraction by Wt: 23.0%
OSHA PEL:100 PPM

=====
Identification =====

Effects of Overexposure:INHALED:ANESTHETIC & IRRITATION TO
AIRWAY;IRRITATION-SKIN/EYE CONTACT;HEADACHE,DIZZY,COMA

=====
First Aid Measures =====

First Aid:INCASE OF CONTACT,FLUSH SKIN AND EYES WITH PLENTY OF WATER
WHILE REMOVEING CONTAMINATED CLOTHING.IF INHALED, REMOVE TO FRESH
AIR.CALL A PHYSICIAN IF SYMPTOMS PERSIST

=====
Fire Fighting Measures =====

Flash Point:30F,

-1C TCC

Lower Limits:0.9

Extinguishing Media:CARBON DIOXIDE/DRY CHEMICAL-SMALL;POLYMER
FOAM-LARGE FIRE

Fire Fighting Procedures:SELF-CONTAINED BREATHING APPARATUS AVAILABLE
FOR FIREMEN

Unusual Fire/Explosion Hazard:CLOSED CONTAINERS EXPOSED TO HEAT MAY
EXPLODE DUE TO PRESSURE BUILD UP

===== Accidental Release Measures =====

Spill Release Procedures:REMOVE ALL SOURCES IF IGNITION(FLAMES,HOT
SURFACES, & ELECTRICAL,STATIC,OR FRICTIONAL SPARKS).AVOID BR
EATHING
VAPORS.VENTILATE AREA. REMOVE WITH INERT ABSORBENT AND NON-SPARKING
TOOLS.

===== Handling and Storage =====

Handling and Storage Precautions:DO NOT STORE ABOVE 120F. STORE LARGE
QUANTITIES IN BUILDINGS DESIGNED AND PROTECTED FOR STORAGE OF NFPA
CLASS ONE FLAMMABLE(OR COMBUSTIBLE) LIQUID

Other Precautions:DO NOT TAKE INTERNALLY,CONTAINERS SHOULD BE GROUNDED
WHEN POURING,AVOID FREE FALL IN EXCESS OF A FEW INCHES,DO NOT FLAME
CUT
,BRAZE, OR WELD COATED MATERIAL WITHOUT VENTILATION

===== Exposure Controls/Personal Protection =====

Respiratory Protection:APPROVED BUREAU OF MINES RESPIRATORS W/PROPER
FILTER OR HOOD

Ventilation:GENERAL DILUTION/LOCAL EXHAUST FOR TLV &LEL SAFETY& WELDING

Protective Gloves:ALOT OF CONTACT

Eye Protection:USE EYEWEAR IF SPLASHING

Other Protective Equipment:PREVENT PROLONGED SKIN CONTACT TO
CONTAMINATED CLOTHING.

Supplemental Safety and Health
BP 79-165 C,