

PENRECO DIVISION OF PENNZOIL CO -- PETROFLUID 822 -- 9150-00-180-6290

=====
Product Identification
=====

Product ID:PETROFLUID 822
MSDS Date:01/01/1985
FSC:9150
NIIN:00-180-6290
MSDS Number: BDGKY
=== Responsible Party ===
Company Name:PENRECO DIVISION OF PENNZOIL CO
Address:700 MILIAM ST PENNZOIL PL
Box:2967
City:HOUSTON
State:TX
ZIP:77252
Country:US
Info Phone Num:800-245-3952
Emergency Phone Num:800-245-3952
CAGE:JO941
=== Contractor Identification ===
Company Name:PENRECO DIVISION, PENNZOTL
Address:700 MILIAM ST PENNZOIL PL
Box:2967
City:HOUSTON
State:TX
ZIP:77252
Country:US
CAGE:JO941
Company Name:PENRECO, DIV OF PENNZOIL CO
Address:700 MILIAM ST
Box:2967
City:HOUSTON
State:TX
ZIP:77252
Country:US
Phone:800-245-3952
CAGE:86459

=====
Composition/Information on Ingredients
=====

Ingred Name:SYNTHETIC OIL

Ingred Name:DIBASIC ACID ESTER

=====
Haza

rd's Identification =====

Effects of Overexposure:EYE: IRRIT: SKIN: IRRIT. INGEST: LOCAL IRRIT OF MUC MEMB OF THROAT, MOUTH, ESOPHAGUS, STOMACH.

===== First Aid Measures =====

First Aid:EYE: WASH IMMEDIATELY WITH WATER FOR 15 MIN. CALL PHYSICIAN. SKIN: WASH WITH SOAP & WATER. REMOVE CONTAMINATED CLOTHING & WASH BEFORE REUSE. INGEST: DO NOT INDUCE VOMITING (ASPIRATION HAZARD)

===== Fire Fighting Measures =====

=

Flash Point Method: COC

Flash Point: 424F, 218C

Extinguishing Media: CO₂, DRY CHEM, FOAM

Fire Fighting Procedures: WATER MAY BE USED TO COOL HEAT-EXPOSED CANS.

Unusual Fire/Explosion Hazard: PROD OF COMBUSTION: CO, CO₂, SMOKE.

MATERIAL MUST BE HEATED ABOVE FLASH POINT TO BE A FIRE HAZARD.

===== Accidental Release Measures =====

Spill Release Procedures: SPREAD OIL DRY MATERIAL ON SPILL & SWEEP UP OR DILUTE SPILL WITH PETROLEUM SOLVENT & WIPE UP. PROVIDE ADEQUATE VENT &

AVOID SOURCES OF IGNITION. STORE IN COVERED MARKED METALLIC CONTAINERS AND DISPOSE OF AS SOON AS POSSIBLE.

===== Handling and Storage =====

Handling and Storage Precautions: STORE IN COVERED MARKED METALLIC CONTAINERS. STORE IN COOL WELL VENTED AREA. CONTROL IGNITION SOURCES. GROUND CANS PRIOR TO PUMPING OR TRANSFERRING.

Other Precautions: FIRE EXTINGUISHERS MUST BE KEPT READILY AVAILABLE & ALL PERSONNEL TRAINED PROPERLY. DO NOT MIX WITH STRONG OXIDANTS. DO

NOT TRANSFER TO UNMARKED CONTAINERS, AUTOIGNITION TEMP: 630F; 332C.

===== Exposure Controls/Personal Protection =====

Respiratory Protection: NIOSH/MSHA APPROVED RESPIRATOR FOR PARTICULAR EXPOS OF CONCERN (MFR)

Ventilation: TO KEEP CONCENTRATION BELOW TLV. USE EXPLOSION-PROOF EQUIP.

Protective Gloves: POLYETHYLENE

Eye Protection: SAFETY GOGGLES WITH FACE SHIELD

Other Protective Equipment: IMPERVIOUS POLYETHYLENE BOOTS/APRON ETC.

Supplemental Safety and Health

TLV=5 M

G/CUM FOR MIST & 500 PPM FOR VAPORS GENERATED UPON HEATING.
CONTAINER: 55 GALLON.

===== Physical/Chemical Properties =====

HCC:V6

Vapor Pres:1

Spec Gravity:0.85

Evaporation Rate & Reference: