

STERLING LACQUER MFG,3150 BRANNON AVE,ST.LOUIS,MO. -- A-7729 -- 8030-00-200-6946

=====  
Product Identification  
=====

Product ID:A-7729

MSDS Date:01/01/1985

FSC:8030

NIIN:00-200-6946

MSDS Number: BDJGR

=== Responsible Party ===

Company Name:STERLING LACQUER MFG,3150 BRANNON AVE,ST.LOUIS,MO.

Emergency Phone Num:314-776-4450

CAGE:22181

=== Contractor Identification ===

Company Name:STERLING LACQUER M

FG

Address:3150 BRANNON AVE

Box:City:ST LOUIS

State:MO

ZIP:63139-1422

Country:US

CAGE:22181

=====  
Composition/Information on Ingredients  
=====

Ingred Name:ETHYL ALCOHOL (ETHANOL)

CAS:64-17-5

RTECS #:KQ6300000

Fraction by Wt: 40.0%

OSHA PEL:1000 PPM

ACGIH TLV:1000 PPM; 9192

Ingred Name:GLYCOL ETHERS

CAS:111-46-6

RTECS #:ID5950000

Fraction by Wt: 42.0%

Ingred Name:AROMATIC HYDROCARBONS

Fraction by Wt: 18.0%

=====  
Hazards Identification  
=====

Effects of Overexposure:EYE AND SKIN CONTACT: PRIMARY IRRITATION.INHALATION: IRRITATION OF THE RESPIRATORY TRACT & NARCOSIS

=====  
First Aid Measures  
=====

First Aid:EYE CONTACT:FLUSH WITH WATER FOR 15 MINUTES.TAKE TO PHYSICIAN.  
SKIN CONTACT:WASH WITH SOAP AND WATER.NOTIFY PHYSICIAN.  
INHALATION:FRESH AIR AND TREATMENT FOR EFFECTS OF SOLVENT FUMES.  
PHYSICIAN CONSULTATION. DO NOT INDUCE VOMITING IF INGESTED.

=====  
Fire  
Fighting Measures  
=====

Flash Point:45F CC  
Lower Limits:1.45  
Upper Limits:11.3  
Extinguishing Media:CO2,FOAM OR DRY CHEMICAL (NFPA) CLASS B  
EXTINGUISHERS.  
Fire Fighting Procedures:NO NOT USE WATER  
Unusual Fire/Explosion Hazard:FLAMMABLE LIQUID NFPA CLASS 1B  
CLASSIFICATION.ISOLATE FROM HEAT,ELECTRICAL EQUIP,SPARKS & OPEN  
FLAME

=====  
Accidental Release Measures  
=====

Spill Release Procedures:REMOVE ALL SOURCES OF IGNITION(FLAMES, HOT  
S  
OURCES,AND ELECTRICAL OR FRICTIONAL SPARKS). AVOID BREATHING  
VAPORS.VENTILATE AREA.REMOVE WITH INERT ABSORBENT AND NON-SPARKING  
TOOLS.

=====  
Handling and Storage  
=====

Handling and Storage Precautions:DO NOT STORE ABOVE 120F. STORE LARGE  
QUANTITIES IN BUILDINGS DESIGNED AND PROTECTED FOR STORAGE OF NFPA  
CLASS 1B FLAMMABLE LIQUIDS.  
Other Precautions:DO NOT TAKE INTERNALLY.WHEN HANDLING LARGE VOLUMES,  
GROUND CONTAINERS WHEN POURING AND AVOID

FREE FALL POURING IN  
EXCESS OF A FEW INCHES.

===== Exposure Controls/Personal Protection =====

Respiratory Protection:APPROVED BUREAU OF MINES DEVICE FOR TYPE  
AREA(CONFINED,RESTRIC.,VENT  
Ventilation:PROVIDE GEN.DILUTION OF LOCAL EXHAUST VENTILATION IN VOLUME  
Protective Gloves:REQUIRED  
Eye Protection:REQUIRED  
Other Protective Equipment:PREVENT PROLONGED SKIN CONTACT TO  
CONTAMINATED CLOTHING  
Supplemental Safety and Health  
CLOSED CONTAINERS MAY EXPLODE WHEN EXPOSED  
TO EXTREME HEAT. KEEP TLV  
BELOW ACCEPTABLE LIMIT.

===== Physical/Chemical Properties =====

HCC:F3  
Boiling Pt:B.P. Text:179  
Vapor Pres:31  
Vapor Density:>1  
Spec Gravity:0.96  
Evaporation Rate & Reference:FASTER THAN NBUATE  
Solubility in Water:SLIGHT  
Appearance and Odor:BLUE LIQUID, SOLVENT ODOR  
Percent Volatiles by Volume:98.0

===== Stability and Reactivity Data =====

Stability Indicator/Materials to Avoid:YES  
NONE  
Hazardous Decompos  
ition Products:NONE

===== Disposal Considerations =====

Waste Disposal Methods:DISPOSE IN ACCORDANCE WITH LOCAL, STATE, AND  
FEDERAL REGULATIONS. INCINERATE IN APPROVED FACILITY. DO NOT  
INCINERATE CLOSED CONTAINERS.

Disclaimer (provided with this information by the compiling agencies):  
This information is formulated for use by elements of the Department  
of Defense. The United States of America in no manner whatsoever,  
expressly or implied, warrants

this information to be accurate and disclaims all liability for its use. Any person utilizing this document should seek competent professional advice to verify and assume responsibility for the suitability of this information to their particular situation.