View NSN Online: https://aerobasegroup.com/nsn/8010-00-297-0549 PRATT AND LAMBERT INC -- 741-612 -- 8010-00-297-0549 Product ID:741-612 MSDS Date:01/01/1985 FSC:8010 NIIN:00-297-0549 MSDS Number: BDVXY === Responsible Party === Company Name: PRATT AND LAMBERT INC Address:945 BURLINGTON City: KANSAS CITY State:MO ZIP:64141 Country:US Emergency Phone Num:316-733-1361 CAGE:92216 === Contractor Identification === Company Name: PRAT T AND LAMBERT INC Address:945 BURLINGTON Box:206 City: KANSAS CITY State:MO ZIP:64141 Country:US CAGE:92216 ======= Composition/Information on Ingredients ======== Ingred Name: NAPHTHA (PETROLEUM SPIRITS OR BENZIN) CAS:8030-30-6 RTECS #:SE7555000 Fraction by Wt: 35.0% OSHA PEL:100 PPM ========== Hazards Identification ===============

Effects of Overexposure:INHALED-ANESTHETIC, IRITATE AIRWAY; SKIN/EYE IRRITATION HEADACHE, DIZZINESS, COMA, CONFUSION

======

| First Aid:INCASE OF CONTACT, FLUSH SKIN AND EYES WITH PLENTY OF WATER WHILE REMOVING CONTAMINATED CLOTHING. IF INHALED, REMOVE TO FRESH AIR. CALL A PHYSICIAN IF SYMPTONS PERSIST. PERFORM ARTIFICIAL RESPIRATION IF BREATHING HAS STOPPED. |
|--|
| ====================================== |
| Flash Point:104 F, 40 C TCC Lower Limits:1.1 Extinguishing Media:CARBON DIOXIDE/DRY CHEMICAL-SMALL; POLYMER FOAM-L ARGE FIRE Fire Fighting Procedures:SELF-CONTAINED BREATHING APPARATUS AVAILABLE FOR FIREMEN Unusual Fire/Explosion Hazard:PRESSURE BUILD-UP FROM EXTREME HEAT MAY CAUSE EXPLOSION.USEWATER TO COOL CANS. FOR FIRE: FOG NOZZLES |
| ========= Accidental Release Measures ========== |
| Spill Release Procedures:REMOVE ALL SOURCES OF IGNITION (FLAMES, HOT SURFACES, & ELECTRICAL, STATIC, OR FRICTIONAL SPARKS). AVOID BREATHING VAPORS. VENTILATE AREA. REMOVE WITH INERT ABSORBENT AND NON-SPARKING TOOLS. |
| =========== Handling and Storage ============= |
| Handling and Storage Precautions:DO NOT STORE ABOVE 120F. STORE LARGE QUANTITIES IN BUILDINGS DESIGNED AND PROTECTED FOR STORAGE OF NFPA CLASSONE FLAMMABLE (OR COMBUSTIBLE) LIQUID. Other Precautions:DO NOT TAKE INTERNALLY,CONTAINERS SHOULD BE GROUNDED WHEN POURING,AVOID FREE FALL IN EXCESS OF A FEW INCHES,DO NOT FLAME CUT,BRAZE, OR WELD COATED MATERIAL WITHOUT VENTILATION. |
| ===== Exposure Controls/Personal Protection ======== |
| Respiratory Protection:APPROVED BUREAU OF MINES RESPIRATORS W/ PROPER FILTER OR HOOD Ventilation:GENERAL DILUTION/LOCAL EXHAUST FOR TLV&LEL SAFETY& WELDING Protective Gloves:ALOT OF CONTACT Eye Protection:USE EYEWEARIF SPLASHING Other Protective Equipment:PREVENT PROLONGED SKIN CONTACT TO CONTAMINATED CLOTHING. Supplemental Safety and Health BOILING RANGE 155-189 C. |
| ========= Physical/Chemical Properties ======= |

======== First Aid Measures ============

======

HCC:F4
Boiling Pt:B.P. Text:311-373 F
Evaporation Rate & Description of the Company of the Compa

======== Stability and Reactivity Data ==========

Stability Indicator/Materials to Avoid:YES Stability Condition to Avoid:FIRES, HEAT, & HOT SURFACES, SPARKS, ELECTRICAL EQUIPMENT

====== Disposal Considerations ==========

Waste Disposal Methods:DISPOSE IN ACCORDANCE WITH LOCAL, STATE, AND FE

DERAL REGULATIONS. INCINERATE IN APPROVED FACILITY. DO NOT INCINERATE CLOSED CONTAINERS.

Disclaimer (provided with this information by the compiling agencies): This information is formulated for use by elements of the Department of Defense. The United States of America in no manner whatsoever, expressly or implied, warrants this information to be accurate and disclaims all liability for its use. Any person utilizing this document should seek competent professional advice to verify a nd

assume responsibility for the suitability of this information to their particular situation.