View NSN Online: https://aerobasegroup.com/nsn/6850-00-551-9577

BIO-TEK,INC. -- CORROSION REMOVING COMPOUND -- 6850-00-551-9577

Product ID:CORROSION REMOVING COMPOUND MSDS Date:01/01/1987 FSC:6850 NIIN:00-551-9577 MSDS Number: BFFCK === Responsible Party === Company Name: BIO-TEK, INC. Address:4680 ALVARADO CANYON ROAD 575 Box:20094 **City:SAN DIEGO** State:CA ZIP:92120-4304 Country:US Info Phone Num:619-286-1786 **Emergency Phone N** um:619-286-1786 CAGE:HO309 === Contractor Identification === Company Name: BIO-TEK INC. Address:2533 N CARSON ST SUITE 2012 Box:City:CARSON CITY State:NV ZIP:89706 Country:US Phone:619-233-7229 CAGE:59557 Company Name: BIO-TEK, INC. Address:4680 ALVARADO CANYON ROAD 575 Box:20094 **City:SAN DIEGO** State:CA ZIP:92120-4304 Country:US Phone:619-286-1786 CAGE:HO309

Ingred Name:PHOSPHORIC ACID (SARA III) CAS:7664-38-2 RTECS #:TB6300000 Fraction by Wt: >56% OSHA PEL:1 MG/M3/3 STEL ACGIH TLV:1 MG/M3/3 STEL; 9192 EPA Rpt Qty:5000 LBS DOT Rpt Qty:5000 LBS

Ingred Name:NON-IONIC SURFACTANT Fraction by Wt: 2.0% ACGIH TLV:NOT SPECIFIED

Effects of Overexposure:INHAL: RESPIRATORY IRRITATION.SKIN AND EYES:IRITATION AND SKIN BURNS. INGEST:SEVER IRRITATION&DAMAGE

First Aid:INHALE:REMOVE TO FRES H AIR, GIVE CPR/O*2 IF NEED;EYES/SKIN:FLUSH W LG AMTS H*20 FOR 15 MIN;INGEST:RINSE MOUTH; GET MEDICAL ATTENTION FOR EYES, BREATHING DIFFICULTY, OR OTHER SYMPTOMS OF OVEREXPOSURE.

Flash Point:NONE

Extinguishing Media:NOT SPECIFIED Unusual Fire/Explosion Hazard:NOT SPECIFIED.BUT IT CAN REACT WITH METALS TO PRODUCE HYDROGEN,A FLAMMABLE GAS.

Spi

II Release Procedures: USE PROPER PERSONAL PROTECTIVE EQUIPMENT. ACID COLLECTED CAN BE NEUTRALIZED WITH SODA ASH, FLUSH WITH LARGE AMOUNT OF WATER AND RECOVER INTO A SUITABLE CONTAINERS FOR DISPOSAL.

Handling and Storage Precautions:STORE IN DRY COOL AREA WITH ADEQUATE VENTILATION.AVOID FREEZING TEMPERATURES BELOW -21C FOR 85,AND -18C FOR 75%.

Other Precautions:DO NOT BREATH MIST.AVOID SKIN AND EYES CONTACT.

===

Respiratory Protection:USE NIOSH APPROVED RESPIRATOR IF IN EXCESS OF TLV FOR ACID MIST. Ventilation:PROVIDE MECHAN(GEN/LOCAL EXHAUST)VENT TO MAINTN