View NSN Online: https://aerobasegroup.com/nsn/9150-01-263-7240

IMPERIAL OIL CO,INC -- MIL-L-17331-G IMP EP TURBINE OIL -- 9150-01-263-7240

Product ID:MIL-L-17331-G IMP EP TURBINE OIL MSDS Date:01/01/1987 FSC:9150 NIIN:01-263-7240 MSDS Number: BGRMY === Responsible Party === Company Name: IMPERIAL OIL CO, INC Address:ORCHARD PL Box:279 City:MORGANVILLE State:NJ ZIP:07751 Country:US Emergency Phone Num:201-591-9400 CAGE:DO955 = == Contractor Identification === Company Name: IMPERIAL OIL CO INC Address: FOOT OF ORCHARD PL Box:279 City:MORGANVILLE State:NJ ZIP:07751 Country:US Phone:732-591-9400/FAX: 732-591-8825 CAGE:58563 Company Name: IMPERIAL OIL CO, INC. Box:279 CAGE:DO955 Company Name: OCTAGON PROCESS INC. Address:596 RIVER ROAD Box:City:EDGEWATER State:NJ ZIP:07020 Country:US Phone:201-945-9400 CAGE:82925

Ingred Name:NON-HAZARDOUS INGREDIENTS Fracti

on	by	Wt:	100%
----	----	-----	------

,
======================================
Effects of Overexposure:NOT GIVEN.
======================================
First Aid:EYES-FLUSH PROMPTLY W/WATER UNTIL IRRITATION SUBSIDES. INGEST-GET PROMPT MED ATTN.
======================================
Flash Point Method:COC Flash Point:440F Extinguishing Media:CARBON DIOXIDE,WATER FOG,FOAM,DRY CHEM. Fire Fighting Procedures:USE NIOSH/MSHA APPROVED SLF-CONTND BREATH APPARATUS. USE WATER SPRAY TO COOL EXPOSED TANKS,DRUMS & PERSONNEL. Unusual Fire/Explosion Hazard:NONE
======================================
Spill Release Procedures:CONTAIN SPILLED MATL W/SAND,EARTH OR OTHER SUITABLE DIKING MATL. RECOVER FREE LIQUID BY PUMPING INTO DRUMS/OTHER SUITABLE CONTNRS. CLEAN AREA W/RAGS OR OTHER ABSORBING MATLS.
======================================
Handling and S torage Precautions:BECOMES VERY VISCOUS WHEN STORED AT LOW TEMPS. CONGEALS AT -12C.
======================================
Respiratory Protection:NOT NORM REQD. Ventilation:NOT NORM REQD. Protective Gloves:NEOPRENE,RUBBER OR PLASTIC. Eye Protection:SAFETY GOGGLES. Other Protective Equipment:NOT REQD. Supplemental Safety and Health
======================================
HCC:V6 Boiling Pt:B.P. Text:>600F Vapor Pres: