

View Online at <https://aerobasegroup.com/nsn/4520-01-331-6565>

**Mounting Method Style:**

Flange type mounting facility

**Body Style:**

Finned, tubular, u shaped

**Terminal Quantity:**

2

**Overall Length:**

17.125 inches

**Effective Heating Length:**

14.000 inches

**Element Radiation Specification:**

Noninfrared

**Element Connection Style:**

Stud type

**Terminal Length:**

1.031 inches

**Mounting Facility Length:**

4.500 inches

**Center To Center Distance Between Mounting Facilities Parallel To Length:**

4.187 inches

**Center To Center Distance Between Mounting Facilities Parallel To Width:**

1.312 inches

**Mounting Facility Width:**

1.625 inches

**Hole Or Slot Quantity:**

4

**Heat Quantity:**

1

**Watt Density Rating:**

56.51 per square inch single voltage

**Length:**

15.000 inches

**End Application:**

Indeeco tag no. Hv sao4001 stage 3

**Maximum Wattage Rating In Watts:**

1180.0 single voltage

**Element Quantity:**

1

**Thread Quantity:**

32 per inch stud

**Voltage In Volts And Current Type:**

260.0 ac single voltage

**Phase:**

Three single voltage

**Special Features:**

Epoxy sealed

**Frequency In Hertz:**

60.0

**Material:**

Steel comp 304 sheath

**Thread Series Designator:**

Unf stud

**Shelf Life:**

N/a

**Unit Of Measure:**

--

**Demilitarization:**

No

**Fig:**

A01900