

View Online at <https://aerobasegroup.com/nsn/4520-01-331-6566>

Mounting Method Style:

Flange type mounting facility

Body Style:

Finned, tubular, u shaped

Terminal Quantity:

2

Overall Length:

13.125 inches

Effective Heating Length:

11.000 inches

Element Radiation Specification:

Noninfrared

Element Connection Style:

Stud type

Terminal Length:

1.031 inches

Mounting Facility Length:

4.500 inches

Center To Center Distance Between Mounting Facilities Parallel To Length:

4.187 inches

Center To Center Distance Between Mounting Facilities Parallel To Width:

1.312 inches

Mounting Facility Width:

1.625 inches

Hole Or Slot Quantity:

4

Heat Quantity:

1

Watt Density Rating:

22.125 per square inch single voltage

Length:

12.000 inches

End Application:

Indeeco tag no. Hv sao4002 stage 1

Maximum Wattage Rating In Watts:

363.0 single voltage

Element Quantity:

1

Thread Size:

0.190 inches stud

Thread Quantity:

32 per inch stud

Voltage In Volts And Current Type:

260.0 ac single voltage

Phase:

Three single voltage

Special Features:

Epoxy sealed

Frequency In Hertz:

60.0

Material:

Steel comp 304 sheath

Thread Series Designator:

Unf stud

Shelf Life:

N/a

Unit Of Measure:

--

Demilitarization:

No

Fiig:

A01900