

View Online at <https://aerobasegroup.com/nsn/4520-01-510-8590>

**Mounting Method Style:**

Flange type mounting facility

**Body Style:**

Cartridge type

**Terminal Quantity:**

2

**Hole Diameter:**

Between 0.245 inches and 0.255 inches

**Overall Length:**

Between 26.500 inches and 27.000 inches

**Element Radiation Specification:**

Noninfrared

**Element Connection Style:**

Wire lead

**Terminal Length:**

24.000 inches

**Mounting Facility Length:**

Between 1.495 inches and 1.560 inches

**Center To Center Distance Between Mounting Facilities Parallel To Length:**

Between 0.975 inches and 1.275 inches

**Mounting Facility Width:**

Between 1.495 inches and 1.560 inches

**Hole Or Slot Quantity:**

3

**Flange Thickness:**

0.065 inches

**Outside Diameter:**

Between 0.561 inches and 0.565 inches

**Heat Quantity:**

1

**Length:**

Between 26.000 inches and 26.500 inches

**End Application:**

Fbr; defrost panelcxcy

**Maximum Wattage Rating In Watts:**

600.0 single voltage

**Element Quantity:**

6

**Voltage In Volts And Current Type:**

440.0 ac single voltage

**Product Name:**

Special tube-in-tube design 9/16 diameter heater for marlo coil

**Phase:**

Single single voltage

**Special Features:**

Mounting flange is 16 ga 304 sst, tackwelded to tube; terminals are 18 ga exane leadwire with 0.875 long silicone rubber sleeving at flange; cavity is sealed with clear epoxy

**Frequency In Hertz:**

60.0

**Material:**

Steel comp 304 sheath

**Shelf Life:**

N/a

**Unit Of Measure:**

--

**Demilitarization:**

No

**Fig:**

A01900