

View Online at <https://aerobasegroup.com/nsn/4540-01-223-6446>

General Description:

Operates between 125 degrees f and minus 20 degrees f; scanner operates between 212 degrees f and minus 40 degrees f; 7 second purge cycle prior to each start; following each purge cycle a 10 second ignition trial occurs; flame failure results in de-energizing the solenoid; shuts off burner motor and ignition transformer; provides mechanical lockout; turns on alarm circuit

Shelf Life:

N/a

Unit Of Measure:

--

Demilitarization:

No

Fig:

A23900