

View Online at <https://aerobasegroup.com/nsn/4710-00-056-8771>

Pipe Size Designation:

4.000 inches

Wall Thickness Designation:

Thickness class 22

First End Style:

Bell

First End Inside Diameter:

5.600 inches

First End Telescoping Length:

3.500 inches

Second End Style:

Spigot

Second End Bead Outside Diameter:

5.300 inches

Second End Relationship With First End:

Not identical

Construction:

Seamless

Maximum Operating Pressure:

50.0 pounds per square inch

Measuring Method And Length:

144.000 inches laying

Material:

Iron

Surface Treatment:

Tar inside

Specification Or Standard:

1 type and a grade and 50 class and 4.0 size

Departure From Cited Designator:

As modified by measuring method and length

Shelf Life:

N/a

Unit Of Measure:

--

Demilitarization:

No

Fiig:

A004a0