

View Online at <https://aerobasegroup.com/nsn/4710-00-202-7910>

**Pipe Size Designation:**

8.000 inches

**Wall Thickness Designation:**

Schedule 20

**First End Style:**

Outside grooved

**First End Groove Width:**

0.438 inches

**First End Groove Diameter:**

8.441 inches

**First End Length From Groove To End:**

0.750 inches

**Welding Method:**

Electric resistance

**Second End Relationship With First End:**

Identical

**Construction:**

Straight seamed

**Measuring Method And Length:**

239.750 inches random and 240.250 inches random

**Special Features:**

0.250 in. Wall thk; 8.625 in. Od

**Material:**

Steel

**Surface Treatment:**

Enamel outside

**Specification Or Standard:**

1 type

**Departure From Cited Document:**

As modified by outside surface

**Shelf Life:**

N/a

**Unit Of Measure:**

--

**Demilitarization:**

No

**Fiig:**

A004a0