

View Online at <https://aerobasegroup.com/nsn/4710-00-202-7911>

**Pipe Size Designation:**

12.000 inches

**Wall Thickness Designation:**

Schedule 30

**First End Style:**

Outside grooved

**First End Groove Width:**

0.500 inches

**First End Groove Diameter:**

12.531 inches

**First End Length From Groove To End:**

0.750 inches

**Welding Method:**

Electric resistance

**Second End Relationship With First End:**

Identical

**Construction:**

Straight seamed

**Measuring Method And Length:**

239.000 inches random and 240.250 inches random

**Special Features:**

0.330 in. Wall thk; 12.750 in. Od

**Material:**

Steel

**Surface Treatment:**

Enamel outside

**Specification Data:**

81349-mil-p-1187e/me/ government specification

**Specification Or Standard:**

1 type

**Shelf Life:**

N/a

**Unit Of Measure:**

--

**Demilitarization:**

No

**Fiig:**

A004a0