

View Online at <https://aerobasegroup.com/nsn/4710-00-226-6289>

Pipe Size Designation:

6.000 inches

Wall Thickness:

0.280 inches

Inside Diameter:

6.065 inches

Outside Diameter:

6.625 inches

Length:

20.000 feet

Hydrostatic Test Pressure:

2000.0 pounds per square inch

End Connection Style:

Plain

Maximum Operating Pressure:

180.0 pounds per square inch

Ingested Liquid Use Approving Agency:

National sanitation testing laboratory

Potable Water Use Approving Agency:

National sanitation testing laboratory

Color:

Colorless

Material:

Plastic, polyvinyl chloride pvc 1120

Material:

Plastic, polyvinyl chloride pvc 1120

Shelf Life:

N/a

Unit Of Measure:

--

Demilitarization:

No

Fiig:

T383-c