

View Online at <https://aerobasegroup.com/nsn/4710-00-237-0624>

**Pipe Size Designation:**

1.000 inches

**Wall Thickness:**

Between 0.133 inches and 0.153 inches

**Inside Diameter:**

1.049 inches

**Outside Diameter:**

1.315 inches

**Length:**

20.000 feet

**Hydrostatic Test Pressure:**

2000.0 pounds per square inch

**End Connection Style:**

Plain

**Maximum Operating Pressure:**

450.0 pounds per square inch

**Ingested Liquid Use Approving Agency:**

National sanitation testing laboratory

**Potable Water Use Approving Agency:**

National sanitation testing laboratory

**Color:**

White

**Material:**

Plastic, polyvinyl chloride

**Material:**

Plastic polyvinyl chloride

**Specification Or Standard:**

1 type and 1 grade and 40 schedule

**Shelf Life:**

N/a

**Unit Of Measure:**

--

**Demilitarization:**

No

**Fig:**

T383-c