

View Online at <https://aerobasegroup.com/nsn/4710-00-237-0624>

Pipe Size Designation:

1.000 inches

Wall Thickness:

Between 0.133 inches and 0.153 inches

Inside Diameter:

1.049 inches

Outside Diameter:

1.315 inches

Length:

20.000 feet

Hydrostatic Test Pressure:

2000.0 pounds per square inch

End Connection Style:

Plain

Maximum Operating Pressure:

450.0 pounds per square inch

Ingested Liquid Use Approving Agency:

National sanitation testing laboratory

Potable Water Use Approving Agency:

National sanitation testing laboratory

Color:

White

Material:

Plastic, polyvinyl chloride

Material:

Plastic polyvinyl chloride

Specification Or Standard:

1 type and 1 grade and 40 schedule

Shelf Life:

N/a

Unit Of Measure:

--

Demilitarization:

No

Fig:

T383-c