

View Online at <https://aerobasegroup.com/nsn/4710-00-263-4173>

**Pipe Size Designation:**

4.000 inches

**Wall Thickness:**

0.337 inches

**Inside Diameter:**

3.826 inches

**Outside Diameter:**

4.500 inches

**Length:**

20.000 feet

**Hydrostatic Test Pressure:**

2000.0 pounds per square inch

**End Connection Style:**

Plain

**Maximum Operating Pressure:**

320.0 pounds per square inch

**Ingested Liquid Use Approving Agency:**

National sanitation foundation testing laboratories, inc

**Potable Water Use Approving Agency:**

National sanitation testing laboratory

**Color:**

Gray

**Material:**

Plastic, polyvinyl chloride, astm d1785, type 1

**Material:**

Plastic, polyvinyl chloride, astm d1785, type 1

**Specification Or Standard:**

1 type and 1 grade and 80 schedule

**Shelf Life:**

N/a

**Unit Of Measure:**

--

**Demilitarization:**

No

**Fig:**

T383-c