

View Online at <https://aerobasegroup.com/nsn/4710-00-541-6618>

Pipe Size Designation:

1.250 inches

Wall Thickness:

Between 0.191 inches and 0.214 inches

Outside Diameter:

1.660 inches

Hydrostatic Test Pressure:

870.0 pounds per square inch

End Connection Style:

Plain

Maximum Operating Pressure:

420.0 pounds per square inch

Coupling:

Not included

Ingested Liquid Use Approving Agency:

National sanitation testing laboratory

Potable Water Use Approving Agency:

National sanitation testing laboratory

Color:

Gray

Material:

Plastic, polyvinyl chloride, pvc 2116, type 2, grade 1

Material:

Plastic, polyvinyl chloride, pvc 2116, type 2, grade 1

Shelf Life:

N/a

Unit Of Measure:

--

Demilitarization:

No

Fiig:

T383-c