

View Online at <https://aerobasegroup.com/nsn/4710-00-551-0543>

**Pipe Size Designation:**

1.500 inches

**Wall Thickness:**

0.225 inches

**Inside Diameter:**

1.450 inches

**Outside Diameter:**

1.900 inches

**Length:**

20.000 feet

**Hydrostatic Test Pressure:**

900.0 pounds per square inch

**End Connection Style:**

Plain

**Maximum Operating Pressure:**

430.0 pounds per square inch

**Ingested Liquid Use Approving Agency:**

National sanitation testing laboratory

**Potable Water Use Approving Agency:**

National sanitation testing laboratory

**Color:**

Gray

**Material:**

Plastic, polyvinyl chloride

**Material:**

Plastic polyvinyl chloride

**Specification Or Standard:**

120 schedule

**Shelf Life:**

N/a

**Unit Of Measure:**

--

**Demilitarization:**

No

**Fig:**

T383-c