

View Online at <https://aerobasegroup.com/nsn/4710-00-554-8693>

Pipe Size Designation:

1.000 inches

Wall Thickness:

0.070 inches

Inside Diameter:

1.049 inches

Outside Diameter:

1.189 inches

Length:

100.000 feet

Hydrostatic Test Pressure:

210.0 pounds per square inch

End Connection Style:

Plain

Maximum Operating Pressure:

100.0 pounds per square inch

Coupling:

Not included

Potable Water Use Approving Agency:

National sanitation testing laboratory

Color:

Black

Material:

Plastic, polyethylene

Material:

Plastic polyethylene

Specification Or Standard:

1 type and a class or b class and 1 grade or 2 grade and 1 size

Shelf Life:

N/a

Unit Of Measure:

--

Demilitarization:

No

Fig:

T383-c