

View Online at <https://aerobasegroup.com/nsn/4710-00-853-4776>

**Pipe Size Designation:**

0.750 inches

**Wall Thickness:**

0.154 inches

**Inside Diameter:**

0.742 inches

**Outside Diameter:**

1.050 inches

**Length:**

10.000 feet

**Hydrostatic Test Pressure:**

1440.0 pounds per square inch

**End Connection Style:**

Plain

**Maximum Operating Pressure:**

690.0 pounds per square inch

**Coupling:**

Not included

**Potable Water Use Approving Agency:**

National sanitation testing laboratory

**Material:**

Plastic, polyvinyl chloride

**Material:**

Plastic polyvinyl chloride

**Specification Or Standard:**

4 type and 1 grade and 80 schedule

**Shelf Life:**

N/a

**Unit Of Measure:**

--

**Demilitarization:**

No

**Fiig:**

T383-c