

View Online at <https://aerobasegroup.com/nsn/4710-00-926-4267>

**Pipe Size Designation:**

0.500 inches

**Wall Thickness:**

0.075 inches

**Inside Diameter:**

0.622 inches

**Length:**

100.000 feet

**Hydrostatic Test Pressure:**

210.0 pounds per square inch

**End Connection Style:**

Plain

**Maximum Operating Pressure:**

100.0 pounds per square inch

**Coupling:**

Not included

**Potable Water Use Approving Agency:**

National sanitation testing laboratory

**Color:**

Black

**Material:**

Plastic, polyethylene

**Material:**

Plastic polyethylene

**Specification Or Standard:**

1 type and a class or b class and 1 grade or 2 grade and 1/2 size

**Shelf Life:**

N/a

**Unit Of Measure:**

--

**Demilitarization:**

No

**Fiig:**

T383-c