

View Online at <https://aerobasegroup.com/nsn/4710-00-938-7835>

Pipe Size Designation:

1.250 inches

Wall Thickness:

0.091 inches

Length:

20.000 feet

Hydrostatic Test Pressure:

1090.0 pounds per square inch

End Connection Style:

Plain

Maximum Operating Pressure:

520.0 pounds per square inch

Coupling:

Not included

Potable Water Use Approving Agency:

National sanitation testing laboratory

Material:

Plastic, polyvinyl chloride

Material:

Plastic polyvinyl chloride

Specification Data:

81346-astm d1785 professional/industrial association specification

Specification Or Standard:

1 type and 1 grade and 80 schedule

Shelf Life:

N/a

Unit Of Measure:

--

Demilitarization:

No

Fiig:

T383-c