

View Online at <https://aerobasegroup.com/nsn/4710-01-012-6709>

Pipe Size Designation:

3.000 inches

Wall Thickness:

0.216 inches

Inside Diameter:

3.068 inches

Outside Diameter:

3.500 inches

Length:

20.000 feet

Hydrostatic Test Pressure:

2000.0 pounds per square inch

End Connection Style:

Plain

Maximum Operating Pressure:

260.0 pounds per square inch

Ingested Liquid Use Approving Agency:

National sanitation foundation testing laboratories, incorporated

Potable Water Use Approving Agency:

National sanitation foundation testing laboratories, incorporated

Special Features:

Schedule 40, pvc1120 not recommended for threading

Material:

Plastic, polyvinyl chloride

Material:

Plastic polyvinyl chloride

Specification Or Standard:

1 grade and 1 type

Shelf Life:

N/a

Unit Of Measure:

--

Demilitarization:

No

Fig:

T383-c