## NSN 5510-00-161-2781

Wood Line Construction Pole - Page 1 of 1



View Online at https://aerobasegroup.com/nsn/5510-00-161-2781

Treatment Type:
Preservative, tt-w-571
Frame Roof Type:
Flat or one way
Preservative Solution Type:
Ammoniacal copper arsenite or chromated copper arsenate, type i, ii or iii or coal-tar creosote or pentachlorophenol
Gain Type And Quantity:
1 mortise or 1 slab
Measuring Method And Length:
65.000 feet specified
Typical Wood Products Use:
Communication and transmission lines, full length preservative treated, gained and bored for two standard crossarms
Service Usage:
Utility
Special Features:
Tfor 2 standard 4.500 in. Crossarms, 2 holes drilled 0.688 in. Dia, spaced 24.000 in. Apart w/center of top hole 10.250 in. Porm 0.250 in.
From peak of roof, poles shall be clean peeled, the american national @standards institute class 3
Supplementary Features:
Typical usefor communication and transmission lines, unit of issueeach
Specification Or Standard:
3 class
Shelf Life:
N/a
Unit Of Measure:
<del></del>
Demilitarization:
No
Fiig:
A173a0