

View Online at <https://aerobasegroup.com/nsn/5510-00-161-3317>

**Treatment Type:**

Preservative, tt-w-571

**Frame Roof Type:**

Flat or one way

**Preservative Solution Type:**

Ammoniacal copper arsenite or chromated copper arsenate, type i, ii or iii or coal-tar creosote or pentachlorophenol

**Species-grade And Grading Association:**

Cedar ungraded unrecognized or douglas fir ungraded unrecognized or larch ungraded unrecognized or pine ungraded unrecognized

**Gain Type And Quantity:**

2 mortise or 1 slab

**Measuring Method And Length:**

30.000 feet specified

**Typical Wood Products Use:**

Preservative treated beams, stringers, posts, timbers, columns and struts for above ground use

**Service Usage:**

Utility

**Special Features:**

Center of top hole 10 1/4 in. From peak of roof

**Supplementary Features:**

Class 5 iaw ansi 05.1; tt-w-571 table 2; clean peeled; unit of issue-ea

**Specification Data:**

81348-mm-p-371 government specification

**Specification Or Standard:**

4 type

**Shelf Life:**

N/a

**Unit Of Measure:**

--

**Demilitarization:**

No

**Fiig:**

A173a0