NSN 5510-00-161-3406

Wood Line Construction Pole - Page 1 of 1



View Online at https://aerobasegroup.com/nsn/5510-00-161-3406 **Treatment Type:** Preservative, tt-w-571 Frame Roof Type: Flat or one way **Maximum Grain Slope:** Any acceptable **Preservative Solution Type:** Ammoniacal copper arsenite or chromated copper arsenate, type i, ii or iii or coal-tar creosote or pentachlorophenol **Species-grade And Grading Association:** Cedar ungraded unrecognized or douglas fir ungraded unrecognized or larch ungraded unrecognized or pine ungraded unrecognized **Gain Type And Quantity:** 2 mortise or 2 slab **Measuring Method And Length:** 75.000 feet specified **Typical Wood Products Use:** Communication and transmission lines, full length preservative treated, gained and bored for two standard crossarms Service Usage: Utility **Supplementary Features:** Typical use--poles for communication and transmission lines, unit of issue--each **Specification Or Standard:** 1 class Shelf Life: N/a **Unit Of Measure: Demilitarization:**

No

Fiig:

A173a0