

View Online at <https://aerobasegroup.com/nsn/5510-00-263-8673>

Treatment Type:

Preservative, tt-w-571

Frame Roof Type:

Flat or one way

Preservative Solution Type:

Ammoniacal copper arsenite or chromated copper arsenate, type i, ii or iii or coal-tar creosote or pentachlorophenol

Species-grade And Grading Association:

Cedar ungraded unrecognized or douglas fir ungraded unrecognized or larch ungraded unrecognized or pine ungraded unrecognized

Gain Type And Quantity:

1 mortise or 1 slab

Measuring Method And Length:

35.000 feet specified

Typical Wood Products Use:

Communication and transmission lines, full length preservative treated, gained and bored for two standard crossarms

Service Usage:

Utility

Special Features:

Sfor 2 standard 4.500 in. Crossarms, 2 holes drilled 0.688 in. Dia, spaced 24.000 in. Apart w/center of top hole 10.250 in. Porm 0.250 in. From peak of roof, poles shall be clean peeled, the american national standards institute class 1

Supplementary Features:

Typical use--for communication and transmission lines, unit of issue--each

Specification Or Standard:

1 class

Shelf Life:

N/a

Unit Of Measure:

--

Demilitarization:

No

Fig:

A173a0