NSN 5510-00-952-8019

Wood Line Construction Pole - Page 1 of 1



View Online at https://aerobasegroup.com/nsn/5510-00-952-8019

Treatment Type:
Preservative, tt-w-571
Preservative Solution Type:
Coal-tar creosote
Species-grade And Grading Association:
Cedar, western ungraded unrecognized
Measuring Method And Length:
40.000 feet specified
Typical Wood Products Use:
Communication and transmission lines, full length preservative treated, gained and bored for two standard crossarms
Minimum Circumference And Location:
25.000 inches top and 43.000 inches butt
Service Usage:
Contact w/ground
Specification Or Standard:
2 class
Shelf Life:
N/a
Unit Of Measure:
Demilitarization:
No
Fiig:
A173a0