---

Wood Line Construction Pole - Page 1 of 1



View Online at https://aerobasegroup.com/nsn/5510-00-952-8025

## **Treatment Type:** Preservative, tt-w-571 **Preservative Solution Type:** Coal-tar creosote Species-grade And Grading Association: Cedar, western ungraded unrecognized Measuring Method And Length: 70.000 feet specified **Typical Wood Products Use:** Communication and transmission lines, full length preservative treated, gained and bored for two standard crossarms Minimum Circumference And Location: 25.000 inches top and 54.000 inches butt Service Usage: Contact w/ground **Specification Or Standard:** 2 class Shelf Life: N/a Unit Of Measure: **Demilitarization:** No Fiig: A173a0