Wood Line Construction Pole - Page 1 of 1



View Online at https://aerobasegroup.com/nsn/5510-00-952-8029

# Treatment Type:

Preservative, tt-w-571

# Preservative Solution Type:

Coal-tar creosote

# Species-grade And Grading Association:

Cedar, western ungraded unrecognized

## Measuring Method And Length:

90.000 feet specified

#### **Typical Wood Products Use:**

Communication and transmission lines, full length preservative treated, gained and bored for two standard crossarms

## Minimum Circumference And Location:

25.000 inches top and 60.000 inches butt

Service Usage:

Contact w/ground

#### **Specification Or Standard:**

2 class

# Shelf Life:

N/a

## Unit Of Measure:

---

## Demilitarization:

No

#### Fiig:

A173a0