

View Online at <https://aerobasegroup.com/nsn/5510-00-983-8807>

Treatment Type:

Preservative, tt-w-571

Frame Roof Type:

Flat or one way

Preservative Solution Type:

Creosote coal-tar solution

Species-grade And Grading Association:

Pine, southern ungraded southern pine inspection bureau

Measuring Method And Length:

16.000 feet specified

Service Usage:

Contact w/ground

Special Features:

9mortise or slab gained for 2 standard 4.500 in. Crossarms, 2 holes drilled 0.688 in. Dia, spaced 24.000 in. Apart w/center of top hole 10.250 in. Porm 0.250 in. From peak of roof, poles shall be clean peeled, the american national standards institute class 7

Supplementary Features:

Typical use--for communication and transmission lines, unit of issue--each

Specification Or Standard:

7 class

Shelf Life:

N/a

Unit Of Measure:

--

Demilitarization:

No

Fiig:

A173a0