

View Online at <https://aerobasegroup.com/nsn/5510-00-983-8808>

Treatment Type:

Preservative, tt-w-571

Frame Roof Type:

Flat or one way

Preservative Solution Type:

Ammoniacal copper arsenite or chromated copper arsenate, type i, ii or iii or coal-tar creosote or pentachlorophenol

Species-grade And Grading Association:

Cedar ungraded unrecognized or douglas fir ungraded unrecognized or larch ungraded unrecognized or pine ungraded unrecognized

Measuring Method And Length:

35.000 feet specified

Typical Wood Products Use:

Communication and transmission lines, full length preservative treated, gained and bored for two standard crossarms

Service Usage:

Utility

Special Features:

9mortise or slab gained for 2 standard 4.500 in. Crossarms, 2 holes drilled 0.688 in. Dia, spaced 24.000 in. Apart w/center of top hole 10.250 in. Porm 0.250 in. From peak of roof, poles shall be clean peeled, the american national standards institute class 7

Supplementary Features:

Typical use--for communication and transmission lines, unit of issue--each

Specification Or Standard:

7 class

Departure From Cited Document:

05-4

Shelf Life:

N/a

Unit Of Measure:

--

Demilitarization:

No

Fig:

A173a0