Wood Line Construction Pole - Page 1 of 1



View Online at https://aerobasegroup.com/nsn/5510-00-983-8814

# **Treatment Type:**

Preservative, tt-w-571

# Frame Roof Type:

One way

# **Preservative Solution Type:**

Ammoniacal copper arsenite or chromated copper arsenate, type i, ii or iii or coal-tar creosote or pentachlorophenol

# Species-grade And Grading Association:

Cedar ungraded unrecognized or douglas fir ungraded unrecognized or larch ungraded unrecognized or pine ungraded unrecognized

# Measuring Method And Length:

16.000 feet specified

# **Typical Wood Products Use:**

Communication and transmission lines, full length preservative treated, gained and bored for two standard crossarms

# Service Usage:

Utility

#### **Special Features:**

Peeling degrees clean

# Supplementary Features:

Typical use--for communication and transmission lines, unit of issue--each

# **Specification Or Standard:**

6 class

# Shelf Life:

N/a

# Unit Of Measure:

--

# Demilitarization:

No

# Fiig:

A173a0