

View Online at <https://aerobasegroup.com/nsn/5920-01-491-3887>

Continuous Current Rating In Amps:

0.500

Circuit Over-current Interruption Type:

Time delay

End Application:

Unit panel

Special Features:

Midget, time delay. Voltage rating 500. Interrupt rating at 125vac-10, 250vac35. Fuse holder code d, in line fuseholder-d.

Supplementary Features:

Midget fuse, fuse current 1/2 amps, fuse holder code d, 13/32 x 1 1/2 inches, 500 volts, 10 kiloamperes interrupt

Shelf Life:

N/a

Unit Of Measure:

--

Demilitarization:

No

Fig:

A01700