

View Online at <https://aerobasegroup.com/nsn/5920-01-491-3887>

**Continuous Current Rating In Amps:**

0.500

**Circuit Over-current Interruption Type:**

Time delay

**End Application:**

Unit panel

**Special Features:**

Midget, time delay. Voltage rating 500. Interrupt rating at 125vac-10, 250vac35. Fuse holder code d, in line fuseholder-d.

**Supplementary Features:**

Midget fuse, fuse current 1/2 amps, fuse holder code d, 13/32 x 1 1/2 inches, 500 volts, 10 kiloamperes interrupt

**Shelf Life:**

N/a

**Unit Of Measure:**

--

**Demilitarization:**

No

**Fiig:**

A01700