## NSN 5925-00-148-8124

Circuit Breaker - Page 1 of 3



View Online at https://aerobasegroup.com/nsn/5925-00-148-8124

**Thread Pitch Diameters:** 

+0.1177 to 0.1214 inches

**Body Style:** 

Multipole-multiple actuator type

**Body Length:** 

Between 2.490 inches and 2.510 inches

**Body Width:** 

Between 2.990 inches and 3.010 inches

**Case Material:** 

**Plastic** 

**Center To Center Distance Between Terminals Parallel To Length:** 

Between 1.928 inches and 1.948 inches

**Center To Center Distance Between Terminals Parallel To Width:** 

Between 0.740 inches and 0.760 inches

Distance Between Centerlines Of Mounting Facilities Parallel To Body Length:

Between 2.052 inches and 2.072 inches

**Switch Contact Arrangement:** 

Single pole, double throw

Distance Between Centerlines Of Mounting Facilities Parallel To Body Width:

Between 0.740 inches and 0.760 inches

**Fragility Factor:** 

Moderately rugged

**Boss Height:** 

Between 0.130 inches and 0.150 inches

**Mounting Surface To Terminal End Distance:** 

Between 2.461 inches and 2.481 inches

**Pole Quantity:** 

.

**Arc Quenching Method:** 

Magnetic blowout

**Mounting Facility Type And Quantity:** 

8 threaded hole

**Storage Type:** 

General purpose warehouse

Thready Qty Per Inch (tpi):

32

**Maximum Continuous Load Current Rating Per Pole:** 

60.0 amperes ac all locations

**Operating Voltage Type And Rating Per Pole In Volts:** 

250.0 ac all locations

Maximum Interrupting Capacity Current Type And Rating Per Pole In Amps:

1000.0 ac all locations



## NSN 5925-00-148-8124 Circuit Breaker - Page 2 of 3 **Circuit Protection Type:** Overcurrent all locations **Trip Release Method:** Magnetic all locations **Trip Release Characteristic:** Time delay first location **Ultimate Trip Rating Of Continuous Current Rating Per Pole In Percent:** 115.0 all locations **Reset Method:** Manual **Main Contact Tripping Mechanism Type: Manual Actuator Type And Quantity:** 4 toggle **Actuator Function:** Trip-reset **Actuator Position Designation:** At each pole **External Actuator Linkage Arrangement:** One, two, three, and four linked **Auxiliary Switch Function And Quantity:** 1 alarm **Internal Trip Release Configuration:**

Series trip third location

**Thread Size:** 

0.138 inches

**Switch Location And Position Designation:** 

Internal at pole one

**Trip Delay Time In Seconds Per Rated Continuous Current:** 

2.200 at 200 pct third location and 20.000 at 200 pct third location

**Inclosure Protection Type For Which Designed:** 

Fungus resistant and vibration resistant

**Switch Terminal Type:** 

Tab, solder lug

**Switch Current Rating And Type In Amps:** 

10.0 ac

**Switch Voltage Rating And Type In Volts:** 

125.0 ac

Frequency In Hertz:

50.0 all locations or 60.0 all locations or 400.0 all locations

**Thread Series Designator:** 

Unc

**Terminal Type And Quantity:** 

10 threaded stud

## NSN 5925-00-148-8124

Circuit Breaker - Page 3 of 3



_					
•	n	<b>0</b> 1	•	12	e:

N/a

**Unit Of Measure:** 

--

Demilitarization:

No

Fiig:

A030a0