## NSN 5925-00-201-7130

Circuit Breaker - Page 1 of 2

---



View Online at https://aerobasegroup.com/nsn/5925-00-201-7130

Case Material:	
Plastic	
Pole Quantity:	
2	
Mounting Facility Type	And Quantity:
2 unthreaded hole	
Maximum Continuous I	oad Current Rating Per Pole:
60.0 amperes ac all locat	ions
Operating Voltage Type	And Rating Per Pole In Volts:
250.0 ac all locations	
Maximum Interrupting	Capacity Current Type And Rating Per Pole In Amps:
5000.0 ac all locations	
Circuit Protection Type	
Overcurrent all locations	
Trip Release Method:	
Magnetic all locations	
Trip Release Character	stic:
Time delay all locations	
Ultimate Trip Rating Of	Continuous Current Rating Per Pole In Percent:
125.0 all locations	
Ultimate Trip Time Per	ole In Seconds:
160.000 all locations and	600.000 all locations
Reset Method:	
Manual	
Main Contact Tripping	/lechanism Type:
Trip free	
Manual Actuator Type	Ind Quantity:
1 toggle	
Actuator Function:	
Reset	
Trip Delay Time In Seco	nds Per Rated Continuous Current:
40.000 at 200 pct all loca	ations and 125.000 at 200 pct all locations and 12.000 at 300 pct all locations and 38.000 at 300 pct all locations
Inclosure Protection Ty	pe For Which Designed:
Fungus resistant and mo	sture resistant
Frequency In Hertz:	
60.0 all locations	
Terminal Type And Qua	ntity:
4 screw	
Shelf Life:	
N/a	
Unit Of Measure:	

## NSN 5925-00-201-7130

Circuit Breaker - Page 2 of 2

Demilitarization:

No

Fiig:

A030a0

