NSN 5925-00-361-1943

Circuit Breaker - Page 1 of 1



View Online at https://aerobasegroup.com/nsn/5925-00-361-1943

Pole Quantity:
3
Features Provided:
Adjustable trip release Maximum Continuous Load Current Rating Per Pole:
300.0 amperes ac all locations
Operating Voltage Type And Rating Per Pole In Volts:
500.0 ac all locations
Maximum Interrupting Capacity Current Type And Rating Per Pole In Amps:
30000.0 ac all locations
Circuit Protection Type:
Overcurrent all locations
Trip Release Method:
Magnetic all locations
Trip Release Characteristic:
Time delay all locations
Reset Method:
Automatic
Manual Actuator Type And Quantity:
1 push button and 1 toggle
Auxiliary Switch Function And Quantity:
1 control
Adjustable Trip Setting Current Range Per Pole In Amps:
+300.0/+600.0 ac all locations
Frequency In Hertz:
60.0 all locations
Terminal Type And Quantity:
6 bus bar
Shelf Life:
N/a
Unit Of Measure:
Demilitarization:
No
Fiig:
A030a0