

View Online at <https://aerobasegroup.com/nsn/5925-01-083-2336>

Pole Quantity:

3

Trip Release Method:

Thermal-magnetic all locations

Trip Release Characteristic:

Time delay all locations

Ultimate Trip Rating Of Continuous Current Rating Per Pole In Percent:

125.0 all locations

Manual Actuator Type And Quantity:

1 toggle

Actuator Function:

Trip-reset

Actuator Position Designation:

At pole two

Trip Release Ambient Temperature Rating:

40.0 degrees celsius all locations

Shelf Life:

N/a

Unit Of Measure:

--

Demilitarization:

No

Fig:

A030a0