NSN 5925-01-088-1496

Circuit Breaker - Page 1 of 2

Body Style:



View Online at https://aerobasegroup.com/nsn/5925-01-088-1496

Multipole-multiple actuator type
Body Length:
5.125 inches
Body Width:
4.144 inches
Case Material:
Plastic
Center To Center Distance Between Terminals Parallel To Width:
1.026 inches
Distance Between Centerlines Of Mounting Facilities Parallel To Body Length
2.750 inches
Distance Between Centerlines Of Mounting Facilities Parallel To Body Width:
1.026 inches
Boss Height:
0.220 inches
Mounting Surface To Terminal End Distance:
3.550 inches
Pole Quantity:
4
Mounting Facility Type And Quantity:
8 threaded hole
Thready Qty Per Inch (tpi):
00
32
Maximum Continuous Load Current Rating Per Pole:
Maximum Continuous Load Current Rating Per Pole:
Maximum Continuous Load Current Rating Per Pole: 100.0 amperes ac all locations and 100.0 amperes dc all locations
Maximum Continuous Load Current Rating Per Pole: 100.0 amperes ac all locations and 100.0 amperes dc all locations Operating Voltage Type And Rating Per Pole In Volts:
Maximum Continuous Load Current Rating Per Pole: 100.0 amperes ac all locations and 100.0 amperes dc all locations Operating Voltage Type And Rating Per Pole In Volts: 240.0 ac third location
Maximum Continuous Load Current Rating Per Pole: 100.0 amperes ac all locations and 100.0 amperes dc all locations Operating Voltage Type And Rating Per Pole In Volts: 240.0 ac third location Maximum Interrupting Capacity Current Type And Rating Per Pole In Amps:
Maximum Continuous Load Current Rating Per Pole: 100.0 amperes ac all locations and 100.0 amperes dc all locations Operating Voltage Type And Rating Per Pole In Volts: 240.0 ac third location Maximum Interrupting Capacity Current Type And Rating Per Pole In Amps: 5000.0 ac all locations and 5000.0 dc all locations
Maximum Continuous Load Current Rating Per Pole: 100.0 amperes ac all locations and 100.0 amperes dc all locations Operating Voltage Type And Rating Per Pole In Volts: 240.0 ac third location Maximum Interrupting Capacity Current Type And Rating Per Pole In Amps: 5000.0 ac all locations and 5000.0 dc all locations Circuit Protection Type:
Maximum Continuous Load Current Rating Per Pole: 100.0 amperes ac all locations and 100.0 amperes dc all locations Operating Voltage Type And Rating Per Pole In Volts: 240.0 ac third location Maximum Interrupting Capacity Current Type And Rating Per Pole In Amps: 5000.0 ac all locations and 5000.0 dc all locations Circuit Protection Type: Overcurrent all locations
Maximum Continuous Load Current Rating Per Pole: 100.0 amperes ac all locations and 100.0 amperes dc all locations Operating Voltage Type And Rating Per Pole In Volts: 240.0 ac third location Maximum Interrupting Capacity Current Type And Rating Per Pole In Amps: 5000.0 ac all locations and 5000.0 dc all locations Circuit Protection Type: Overcurrent all locations Trip Release Method:
Maximum Continuous Load Current Rating Per Pole: 100.0 amperes ac all locations and 100.0 amperes dc all locations Operating Voltage Type And Rating Per Pole In Volts: 240.0 ac third location Maximum Interrupting Capacity Current Type And Rating Per Pole In Amps: 5000.0 ac all locations and 5000.0 dc all locations Circuit Protection Type: Overcurrent all locations Trip Release Method: Magnetic all locations
Maximum Continuous Load Current Rating Per Pole: 100.0 amperes ac all locations and 100.0 amperes dc all locations Operating Voltage Type And Rating Per Pole In Volts: 240.0 ac third location Maximum Interrupting Capacity Current Type And Rating Per Pole In Amps: 5000.0 ac all locations and 5000.0 dc all locations Circuit Protection Type: Overcurrent all locations Trip Release Method: Magnetic all locations Trip Release Characteristic:
Maximum Continuous Load Current Rating Per Pole: 100.0 amperes ac all locations and 100.0 amperes dc all locations Operating Voltage Type And Rating Per Pole In Volts: 240.0 ac third location Maximum Interrupting Capacity Current Type And Rating Per Pole In Amps: 5000.0 ac all locations and 5000.0 dc all locations Circuit Protection Type: Overcurrent all locations Trip Release Method: Magnetic all locations Trip Release Characteristic: Instantaneous all locations and time delay all locations
Maximum Continuous Load Current Rating Per Pole: 100.0 amperes ac all locations and 100.0 amperes dc all locations Operating Voltage Type And Rating Per Pole In Volts: 240.0 ac third location Maximum Interrupting Capacity Current Type And Rating Per Pole In Amps: 5000.0 ac all locations and 5000.0 dc all locations Circuit Protection Type: Overcurrent all locations Trip Release Method: Magnetic all locations Trip Release Characteristic: Instantaneous all locations and time delay all locations Ultimate Trip Rating Of Continuous Current Rating Per Pole In Percent:
Maximum Continuous Load Current Rating Per Pole: 100.0 amperes ac all locations and 100.0 amperes dc all locations Operating Voltage Type And Rating Per Pole In Volts: 240.0 ac third location Maximum Interrupting Capacity Current Type And Rating Per Pole In Amps: 5000.0 ac all locations and 5000.0 dc all locations Circuit Protection Type: Overcurrent all locations Trip Release Method: Magnetic all locations Trip Release Characteristic: Instantaneous all locations and time delay all locations Ultimate Trip Rating Of Continuous Current Rating Per Pole In Percent: 125.0 all locations
Maximum Continuous Load Current Rating Per Pole: 100.0 amperes ac all locations and 100.0 amperes dc all locations Operating Voltage Type And Rating Per Pole In Volts: 240.0 ac third location Maximum Interrupting Capacity Current Type And Rating Per Pole In Amps: 5000.0 ac all locations and 5000.0 dc all locations Circuit Protection Type: Overcurrent all locations Trip Release Method: Magnetic all locations Trip Release Characteristic: Instantaneous all locations and time delay all locations Ultimate Trip Rating Of Continuous Current Rating Per Pole In Percent: 125.0 all locations Reset Method:
Maximum Continuous Load Current Rating Per Pole: 100.0 amperes ac all locations and 100.0 amperes dc all locations Operating Voltage Type And Rating Per Pole In Volts: 240.0 ac third location Maximum Interrupting Capacity Current Type And Rating Per Pole In Amps: 5000.0 ac all locations and 5000.0 dc all locations Circuit Protection Type: Overcurrent all locations Trip Release Method: Magnetic all locations Trip Release Characteristic: Instantaneous all locations and time delay all locations Ultimate Trip Rating Of Continuous Current Rating Per Pole In Percent: 125.0 all locations Reset Method: Manual

NSN 5925-01-088-1496 Circuit Breaker - Page 2 of 2



Manual Actuator Type And Quantity:
4 toggle
Actuator Function:
Trip-reset
Actuator Position Designation:
At each pole
External Actuator Linkage Arrangement:
One, two, three, and four linked
Internal Trip Release Configuration:
Series trip third location
Thread Size:
0.138 inches
Trip Delay Time In Seconds Per Rated Continuous Current:
2.000 at 200 pct all locations and 10.000 at 200 pct all locations
Inclosure Protection Type For Which Designed:
Fungus resistant
Frequency In Hertz:
60.0 third location
Thread Series Designator:
Unc
Terminal Type And Quantity:
10 threaded stud
Shelf Life:
N/a
Unit Of Measure:
Demilitarization:
No
Fiig:
A030a0