NSN 5925-01-137-2115

Circuit Breaker - Page 1 of 1



View Online at https://aerobasegroup.com/nsn/5925-01-137-2115

Pole Quantity:
3
Maximum Continuous Load Current Rating Per Pole:
250.0 amperes ac all locations
Operating Voltage Type And Rating Per Pole In Volts:
500.0 ac all locations and 250.0 dc all locations
Maximum Interrupting Capacity Current Type And Rating Per Pole In Amps:
20000.0 ac all locations and 15000.0 dc all locations
Circuit Protection Type:
Overcurrent all locations
Trip Release Method:
Magnetic all locations
Trip Release Characteristic:
Instantaneous all locations and time delay all locations
Ultimate Trip Rating Of Continuous Current Rating Per Pole In Percent:
150.0 all locations
Reset Method:
Manual
Frequency In Hertz:
60.0 all locations or 400.0 all locations
Shelf Life:
N/a
Unit Of Measure:
Demilitarization:
No
Fiig:
A030a0