

View Online at <https://aerobasegroup.com/nsn/5925-01-248-2202>

**Body Style:**

Multipole-multiple actuator type

**Bushing Length:**

0.130 inches

**Body Length:**

2.000 inches

**Body Width:**

1.515 inches

**Case Material:**

Metal

**Center To Center Distance Between Terminals Parallel To Length:**

1.530 inches

**Center To Center Distance Between Terminals Parallel To Width:**

0.750 inches

**Distance Between Centerlines Of Mounting Facilities Parallel To Body Length:**

1.660 inches

**Mounting Surface To Terminal End Distance:**

2.032 inches

**Pole Quantity:**

2

**Mounting Facility Type And Quantity:**

2 threaded hole

**Thready Qty Per Inch (tpi):**

32

**Maximum Continuous Load Current Rating Per Pole:**

15.0 amperes ac all locations

**Operating Voltage Type And Rating Per Pole In Volts:**

250.0 ac all locations and 65.0 dc all locations

**Maximum Interrupting Capacity Current Type And Rating Per Pole In Amps:**

3500.0 ac all locations

**Circuit Protection Type:**

Overcurrent all locations

**Trip Release Method:**

Magnetic-hydraulic all locations

**Trip Release Characteristic:**

Time delay all locations

**Ultimate Trip Rating Of Continuous Current Rating Per Pole In Percent:**

125.0 all locations

**Reset Method:**

Manual

**Main Contact Tripping Mechanism Type:**

Trip free

**Manual Actuator Type And Quantity:**

1 toggle

**Internal Trip Release Configuration:**

Series trip all locations

**Thread Size:**

0.138 inches

**Trip Delay Time In Seconds Per Rated Continuous Current:**

0.700 at 125 pct all locations and 12.000 at 125 pct all locations and 0.008 at 1000 pct all locations and 0.100 at 1000 pct all locations

**Inclosure Protection Type For Which Designed:**

Moisture resistant and corrosion resistant and vibration resistant

**Frequency In Hertz:**

50.0 all locations or 60.0 all locations

**Thread Series Designator:**

Unc

**Terminal Type And Quantity:**

4 screw

**Shelf Life:**

N/a

**Unit Of Measure:**

--

**Demilitarization:**

No

**Fiig:**

A030a0