NSN 5925-01-344-6478

Circuit Breaker - Page 1 of 1



View Online at https://aerobasegroup.com/nsn/5925-01-344-6478

Pole Quantity:

3

Maximum Continuous Load Current Rating Per Pole:

800.0 amperes ac all locations

Operating Voltage Type And Rating Per Pole In Volts:

500.0 ac all locations

Maximum Interrupting Capacity Current Type And Rating Per Pole In Amps:

85000.0 ac all locations

Circuit Protection Type:

Overcurrent all locations

Trip Release Method:

Magnetic all locations

Trip Release Characteristic:

Instantaneous all locations and time delay all locations

Reset Method:

Manual

Frequency In Hertz:

60.0 all locations

Specification Or Standard:

Acb-1600hr type

Shelf Life:

N/a

Unit Of Measure:

Demilitarization:

No

Fiig:

A030a0