NSN 5925-01-344-6478

Circuit Breaker - Page 1 of 1



View Online at https://aerobasegroup.com/nsn/5925-01-344-6478

Maximum Continuous Load Current Rating Per Pole: 800.0 amperes ac all locations Operating Voltage Type And Rating Per Pole In Volts: 500.0 ac all locations
800.0 amperes ac all locations Operating Voltage Type And Rating Per Pole In Volts: 500.0 ac all locations
Operating Voltage Type And Rating Per Pole In Volts: 500.0 ac all locations
500.0 ac all locations
Maximum Interrupting Capacity Current Type And Rating Per Pole In Amps:
85000.0 ac all locations
Circuit Protection Type:
Overcurrent all locations
Trip Release Method:
Magnetic all locations
Trip Release Characteristic:
Instantaneous all locations and time delay all locations
Reset Method:
Manual
Frequency In Hertz:
60.0 all locations
Specification Or Standard:
Acb-1600hr type
Shelf Life:
N/a
Unit Of Measure:
Demilitarization:
No
Fiig:
A030a0