## NSN 5925-01-380-6305

Circuit Breaker - Page 1 of 1



View Online at https://aerobasegroup.com/nsn/5925-01-380-6305

Pole Quantity:
3
Maximum Continuous Load Current Rating Per Pole:
20.0 amperes ac all locations
Operating Voltage Type And Rating Per Pole In Volts:
120.0 ac all locations
<b>Maximum Interrupting Capacity Current Type And Rating Per Pole In Amps:</b>
5000.0 ac all locations
Circuit Protection Type:
Overcurrent all locations
Trip Release Method:
Magnetic-hydraulic all locations
Trip Release Characteristic:
Time delay all locations
Ultimate Trip Rating Of Continuous Current Rating Per Pole In Percent:
125.0 all locations
Internal Trip Release Configuration:
Series trip all locations
Trip Delay Time In Seconds Per Rated Continuous Current:
2.000 at 100 pct all locations and 10.000 at 100 pct all locations
Frequency In Hertz:
50.0 all locations or 60.0 all locations
Shelf Life:
N/a
Unit Of Measure:
Demilitarization:
No
Fiig:
A030a0