## NSN 5925-01-393-7918

Circuit Breaker - Page 1 of 1



View Online at https://aerobasegroup.com/nsn/5925-01-393-7918

View Online at https://aerobasegroup.com/nsn/5925-01-393-7918
Pole Quantity:
2
Maximum Continuous Load Current Rating Per Pole:
3.0 amperes ac all locations
Operating Voltage Type And Rating Per Pole In Volts:
240.0 ac all locations
Maximum Interrupting Capacity Current Type And Rating Per Pole In Amps:
1000.0 ac all locations
Circuit Protection Type:
Overcurrent all locations
Trip Release Method:
Magnetic all locations
Trip Release Characteristic:
Time delay all locations
Ultimate Trip Rating Of Continuous Current Rating Per Pole In Percent:
125.0 all locations
Internal Trip Release Configuration:
Series trip all locations
Trip Delay Time In Seconds Per Rated Continuous Current:
0.050 at 200 pct all locations and 10.000 at 200 pct all locations
Frequency In Hertz:
60.0 all locations
Test Data Document:
81349-mil-c-55629 specification (includes engineering type bulletins, brochures, etc., that reflect specification type data in specification
format; excludes commercial catalogs, industry directories, and similar trade publications, reflecting general type data on certain
environmental and performance requirements and test conditions that are shown as "typical", "average", "", etc.).
Terminal Type And Quantity:
4 tab w/screw
Specification Data:
8134955629/10 government standard
Shelf Life:
N/a
Unit Of Measure:
<del></del>
Demilitarization:
No
Fiig:
A030a0