# NSN 5925-01-393-7918

Circuit Breaker - Page 1 of 1



View Online at https://aerobasegroup.com/nsn/5925-01-393-7918

## **Pole Quantity:**

#### 2

## Maximum Continuous Load Current Rating Per Pole:

3.0 amperes ac all locations

## Operating Voltage Type And Rating Per Pole In Volts:

240.0 ac all locations

## Maximum Interrupting Capacity Current Type And Rating Per Pole In Amps:

1000.0 ac all locations

#### **Circuit Protection Type:**

Overcurrent all locations

#### Trip Release Method:

Magnetic all locations

#### Trip Release Characteristic:

Time delay all locations

## Ultimate Trip Rating Of Continuous Current Rating Per Pole In Percent:

125.0 all locations

## Internal Trip Release Configuration:

Series trip all locations

## Trip Delay Time In Seconds Per Rated Continuous Current:

0.050 at 200 pct all locations and 10.000 at 200 pct all locations

## Frequency In Hertz:

60.0 all locations

#### **Test Data Document:**

81349-mil-c-55629 specification (includes engineering type bulletins, brochures, etc., that reflect specification type data in specification format; excludes commercial catalogs, industry directories, and similar trade publications, reflecting general type data on certain environmental and performance requirements and test conditions that are shown as "typical", "average", "", etc.).

#### **Terminal Type And Quantity:**

4 tab w/screw

**Specification Data:** 

81349--55629/10 government standard

Shelf Life:

N/a

#### Unit Of Measure:

---

```
Demilitarization:
```

No

Fiig:

A030a0