## NSN 5925-01-409-1885

Circuit Breaker - Page 1 of 1



View Online at https://aerobasegroup.com/nsn/5925-01-409-1885
Pole Quantity:
3
Maximum Continuous Load Current Rating Per Pole:
12.5 amperes ac all locations and 12.5 amperes dc all locations
Operating Voltage Type And Rating Per Pole In Volts:
240.0 ac all locations and 50.0 dc all locations
Maximum Interrupting Capacity Current Type And Rating Per Pole In Amps:
300.0 ac all locations and 500.0 dc all locations
Circuit Protection Type:
Overcurrent all locations
Trip Release Method:
Magnetic all locations
Trip Release Characteristic:
Time delay all locations
Ultimate Trip Rating Of Continuous Current Rating Per Pole In Percent:
135.0 all locations
Auxiliary Switch Function And Quantity:
1 alarm
Internal Trip Release Configuration:
Series trip all locations
Trip Delay Time In Seconds Per Rated Continuous Current:
0.055 at 200 pct all locations and 0.950 at 200 pct all locations
Frequency In Hertz:
60.0 all locations or 400.0 all locations
Shelf Life:
N/a
Unit Of Measure:
Demilitarization:
No
Fiig:
A030a0